

CERTIFICATE OF ANALYSIS

Fulmont Laboratory & Consultants
 219 Noonan Road
 Ft. Johnson, New York 12070
 Phone/Fax: (518) 842-5171

Date: November 27, 2016

Sample ID: 16122

Date Analyzed: 11/19/16

WO Number: 160929122

Customer: OESJ Central School District

Collection Date: 9/29/16

Address: 61 Monroe Street, St. Johnsville, New York 13452

Collection Time: See Chart

Sample Location: DHR/P Tech School

Collected by: Angelo E. Finateri

Sample Point: See Chart

Potable: Yes

Water Source: Municipal Water

Grab/Composite: Grab

Chlorinated: Yes

Receipt Temp: Room Temp

Sample #	OESJ – DHR/P Tech School Sample Point	Collection Time	Date	Test Result (mg/l)	MCL (mg/l)	Qualifier	Method
50	Rm 121 bathroom faucet	5:39 AM	9/29/16	0.015	0.015	X	SM3113B
31	Drinking fountain #1 near Headstart (low)	5:51 AM	9/29/16	<0.001	0.015		SM3113B
51	Drinking fountain #2 near Headstart (high)	5:51 AM	9/29/16	0.001	0.015		SM3113B
55	Rm 126 faucet	5:55 AM	9/29/16	0.005	0.015		SM3113B
48	Rm 125 faucet	5:54 AM	9/29/16	0.003	0.015		SM3113B
46	Rm 125 bathroom faucet	5:53 AM	9/29/16	0.006	0.015		SM3113B
43	Principal's office bathroom faucet	5:25 AM	9/29/16	0.006	0.015		SM3113B
23	Nurse's office faucet	5:24 AM	9/29/16	0.003	0.015		SM3113B
52	Nurse's office bathroom faucet	5:25 AM	9/29/16	0.002	0.015		SM3113B
1	Food Pantry room faucet	5:23 AM	9/29/16	0.010	0.015		SM3113B
15	Rm 107 sink	5:23 AM	9/29/16	0.010	0.015		SM3113B
10	1st floor Boy's bathroom faucet #1 (left)	5:21 AM	9/29/16	0.002	0.015		SM3113B
40	1st floor Boy's bathroom faucet #2 (right)	5:21 AM	9/29/16	0.004	0.015		SM3113B
5	Drinking fountain near 1st floor restroom	5:19 AM	9/29/16	0.002	0.015		SM3113B
14	1st floor Girl's restroom faucet #1 (left)	5:18 AM	9/29/16	0.004	0.015		SM3113B
27	1st floor Girl's restroom faucet #2 (right)	5:18 AM	9/29/16	0.004	0.015		SM3113B
28	1st floor Faculty room faucet	5:17 AM	9/29/16	0.012	0.015		SM3113B
6	Rm 104 faucet	5:16 AM	9/29/16	0.003	0.015		SM3113B
11	Finance division room faucet	5:15 AM	9/29/16	0.006	0.015		SM3113B
25	Finance division bathroom faucet	5:15 AM	9/29/16	0.012	0.015		SM3113B
3	Rm 103 faucet (leaking) #1	5:12 AM	9/29/16	0.007	0.015		SM3113B
18	Rm 103 faucet (leaking) #2	5:12 AM	9/29/16	0.012	0.015		SM3113B
37	Rm 103 bathroom faucet	5:13 AM	9/29/16	0.012	0.015		SM3113B
2	Rm 102 faucet	5:10 AM	9/29/16	0.013	0.015		SM3113B

CERTIFICATE OF ANALYSIS

Fulmont Laboratory & Consultants
 219 Noonan Road
 Ft. Johnson, New York 12070
 Phone/Fax: (518) 842-5171

Date: November 27, 2016

Sample ID: 16122

Date Analyzed: 11/19/16

WO Number: 160929122

Customer: OESJ Central School District

Collection Date: 9/29/16

Address: 61 Monroe Street, St. Johnsville, New York 13452

Collection Time: See Chart

Sample Location: DHR/P Tech School

Collected by: Angelo E. Finateri

Sample Point: See Chart

Potable: Yes

Water Source: Municipal Water

Grab/Composite: Grab

Chlorinated: Yes

Receipt Temp: Room Temp

Sample #	OESJ – DHR/P Tech School Sample Point	Collection Time	Date	Test Result (mg/l)	MCL (mg/l)	Qualifiers	Method
22	Kitchen faucet #1 (small)	5:26 AM	9/29/16	0.010	0.015		SM3113B
21	Kitchen faucet #2 ®	5:29 AM	9/29/16	0.008	0.015		SM3113B
12	Drinking fountain next to kitchen	5:32 AM	9/29/16	0.001	0.015		SM3113B
8	Women's staff bathroom faucet(near gym/auditorium)	5:33 AM	9/29/16	0.007	0.015		SM3113B
7	Men's staff bathroom faucet(near gym/auditorium)	5:34 AM	9/29/16	0.003	0.015		SM3113B
19	Faculty room faucet	5:45 AM	9/29/16	0.011	0.015		SM3113B
34	Boy's locker room faucet	5:46 AM	9/29/16	0.013	0.015		SM3113B
16	Boy's locker room bubbler	5:47 AM	9/29/16	0.012	0.015		SM3113B
38	Girl's locker room faucet	5:48 AM	9/29/16	0.009	0.015		SM3113B
44	Girl's locker room bubbler (leaking)	5:48 AM	9/29/16	0.017	0.015	X	SM3113B
30	Rm 117 faucet	5:35 AM	9/29/16	0.015	0.015	X	SM3113B
17	Rm 117 bathroom faucet	5:35 AM	9/29/16	0.014	0.015		SM3113B
29	Rm 118 faucet	5:36 AM	9/29/16	0.017	0.015	X	SM3113B
49	Rm 118 bathroom faucet	5:37 AM	9/29/16	0.011	0.015		SM3113B
56	Rm 119 faucet	5:37 AM	9/29/16	0.016	0.015	X	SM3113B
32	Rm 119 bathroom faucet	5:38 AM	9/29/16	0.014	0.015		SM3113B
33	Custodial/maintenance room faucet	5:42 AM	9/29/16	0.003	0.015		SM3113B
65	Custodial/maintenance room bubbler	5:42 AM	9/29/16	0.002	0.015		SM3113B
9	Old 1st grade room faucet	5:43 AM	9/29/16	0.002	0.015		SM3113B
20	Old 1st grade room bubbler	5:43 AM	9/29/16	0.001	0.015		SM3113B
58	Rm 120 faucet	5:40 AM	9/29/16	0.016	0.015	X	SM3113B
59	Rm 120 bathroom faucet	5:41 AM	9/29/16	0.011	0.015		SM3113B
53	Rm 121 faucet	5:39 AM	9/29/16	0.037	0.015	X	SM3113B
13	Rm 102 bathroom faucet	5:11 AM	9/29/16	0.004	0.015		SM3113B

CERTIFICATE OF ANALYSIS

Fulmont Laboratory & Consultants
 219 Noonan Road
 Ft. Johnson, New York 12070
 Phone/Fax: (518) 842-5171

Date: November 27, 2016

Sample ID: 16122

Date Analyzed: 11/19/16

WO Number: 160929122

Customer: OESJ Central School District

Collection Date: 9/29/16

Address: 61 Monroe Street, St. Johnsville, New York 13452

Collection Time: See Chart

Sample Location: DHR/P Tech School

Collected by: Angelo E. Finateri

Sample Point: See Chart

Potable: Yes

Water Source: Municipal Water

Grab/Composite: Grab

Chlorinated: Yes

Receipt Temp: Room Temp

Sample #	OESJ – DHR/P Tech School Sample Point	Collection Time	Date	Test Result (mg/l)	MCL (mg/l)	Qualifiers	Method
64	Rm 208 faucet	6:10 AM	9/29/16	0.003	0.015		SM3113B
63	2nd floor staff bathroom	6:09 AM	9/29/16	0.004	0.015		SM3113B
41	2nd floor Girl's bathroom faucet #1 (left)	6:07 AM	9/29/16	0.004	0.015		SM3113B
47	2nd floor Girl's bathroom faucet #2 (right)	6:08 AM	9/29/16	0.006	0.015		SM3113B
60	2nd floor drinking fountain by restrooms	6:05 AM	9/29/16	0.002	0.015		SM3113B
39	2nd floor Boy's bathroom faucet #1 (left)	6:06 AM	9/29/16	0.044	0.015	X	SM3113B
35	2nd floor Boy's bathroom faucet #2 (right)	6:06 AM	9/29/16	0.004	0.015		SM3113B
57	Rm 207 faucet	6:04 AM	9/29/16	0.019	0.015	X	SM3113B
61	Rm 206 faucet	6:03 AM	9/29/16	0.049	0.015	X	SM3113B
62	Rm 205 faucet	6:02 AM	9/29/16	0.008	0.015		SM3113B
54	Rm 204 faucet	6:02 AM	9/29/16	0.014	0.015		SM3113B
36	Rm 203 faucet	6:01 AM	9/29/16	0.030	0.015	X	SM3113B
45	Rm 202 office faucet	6:00 AM	9/29/16	0.006	0.015		SM3113B
42	Rm 225 faucet	5:57 AM	9/29/16	0.004	0.015		SM3113B
26	Rm 226 faucet	5:58 AM	9/29/16	0.011	0.015		SM3113B
24	Kitchen #2 (left)	5:28 AM	9/29/16	0.005	0.015		SM3113B
X	Ice Machine - Kitchen	5:30 AM	9/29/16	<0.001	0.015		SM3113B

CERTIFICATE OF ANALYSIS

Fulmont Laboratory & Consultants
 219 Noonan Road
 Ft. Johnson, New York 12070
 Phone/Fax: (518) 842-5171

Date: November 27, 2016
 Sample ID: 16122
 Date Analyzed: 11/19/16
 WO Number: 160929122

Customer: OESJ Central School District	Collection Date: 9/29/16
Address: 61 Monroe Street, St. Johnsville, New York 13452	Collection Time: See Chart
Sample Location: DHR/P Tech School	Collected by: Angelo E. Finateri
Sample Point: See Chart	Potable: Yes
Water Source: Municipal Water	Grab/Composite: Grab
Chlorinated: Yes	Receipt Temp: Room Temp

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Comments:

Not all test results are within acceptable limits, please consult chart. Test procedures for all analyses meet NELAC requirements unless noted. If you have any questions, please call the laboratory.

Qualifiers Key:

X - Exceeds maximum contamination limit	R - Duplication outside acceptance limits	H - Hold time exceeded
T - Temperature outside specifications	A - Sample contained air bubble or headspace	B - Analyte detected in blank
S(+/-) Lab control sample outside acceptable limits	M(+/-) Matrix spike recovery outside acceptance limits	
(+) Result may be biased high		
(-) Result may be biased low		

Legend:

< = Less than
 > = Greater than
 ≈ = Approximately
 NP = Not Provided
 mg/l = milligrams per liter = ppm
 ppm = parts per million
 µg/l = micrograms per liter = ppb
 ppb = parts per billion
 gpg = grains per gallon
 MCL = Maximum Contaminant Level
 SM = Standard Methods For the Examination of Water and Wastewater

Reviewed by Angelo E. Finateri Angelo E. Finateri

Environmental Laboratory NYSDOH E.L.A.P. #10350